



Pilot Testing and Evaluation of Three Filtration Technologies for the Eugene / Springfield Wastewater Treatment Plant

2009 PNCWA Annual Conference

Boise, ID

September 15, 2009

By:

Bill Bennett and Yan Seiner, P.E.

Metropolitan Wastewater Management Commission

**Onder Caliskaner, Ph.D., P.E., Steve Celeste, P.E., and Kevin Farthing, P.E.
Kennedy/Jenks Consultants**

Metropolitan Wastewater Management Commission



partners in wastewater management

Kennedy/Jenks Consultants
Engineers & Scientists

Presentation Overview

- Project Overview
- Operational Perspective
- Pilot testing systems
- Pilot testing results
- Questions





About MWMC

- Formed as a partnership between Eugene, Springfield, and Lane County. Established in 1978 to serve as recipient for EPA funding of new treatment facilities.
- City of Eugene operates and maintains treatment plant, biosolids facility and lift stations.
- City of Springfield provides administrative support of the regional wastewater program including management of the Capital Improvements Program.



Eugene/Springfield WPCF

Current ADWF = 25 mgd
Design ADWF = 49 mgd
Design AWWF = 75 mgd

Treatment Processes:

- **Screening/Grit Removal**
- **Primary Sedimentation**
- **Selector Activated Sludge**
- **Secondary Clarification**
- **Chlorine Disinfection**
- **Dechlorination**
- **Willamette River Discharge**



MWMC Facilities Plan

Cost-effective solution for regional for wastewater needs through 2025.

Established in a joint effort between MWMC and CH2M Hill.

Adopted in 2004

Tertiary filtration one of ten major capital improvement projects.



Tertiary Filter Project

From *MWMC Facilities Plan*:

- Phase 1: 11 mgd filtration capacity
- Year 2025: 33 mgd filtration capacity
- Comply with effluent TSS limits
- Produce Class A recycled water
- Placeholder for future design



Project Team

Operation and Maintenance, City of Eugene

- **Bill Bennett, Filtration Pilot System O&M Lead**
- Steve Barnhardt
- Rick Clark
- Kim Olsen
- Dennis Gabrielson
- Matt Hays
- Chris Jeffress
- Tim Bridgeford

Engineering

- **Yan Seiner, City of Springfield, MWMC Project Manager**
- **Onder Caliskaner, Kennedy Jenks, Tertiary Filtration / Pilot Testing Process Lead**
- Kevin Farthing, Kennedy Jenks, Pilot Testing Staff Engineer
- Steve Celeste, Kennedy Jenks, Tertiary Filtration Project Manager



Project overview

Approach

Step 1. Filtration technology alternatives evaluation/selection

Outcome: Select three technologies for pilot testing

Step 2. Manufacturer selection for pilot testing: request for information process

Outcome: Select one manufacturer for each selected technology

Step 3. Conduct pilot testing

Outcome: Evaluate technology alternatives

Step 4. Preliminary design

Outcome: Select technology upon which to base design

Step 5. Design

Step 6. Bidding

Step 7. Construction



Project objectives

Comply with permit requirements

Comply with Class A recycled water requirements

Minimize energy demands

Minimize chemical use

Minimize impacts to other processes

Flexible operations

Maintainable


Expandable

Minimize footprint




Project Overview

Simplified flow diagram for Effluent TSS Removal



Project Overview

Simplified flow diagram for Class A Recycled Water





Tertiary Pilot Filter Testing An Operational Perspective

Eugene, Oregon

July – November 2008



Metropolitan Wastewater Management Commission



partners in wastewater management

Kennedy/Jenks Consultants
Engineers & Scientists



Pilot Filter Testing: Expectations

Meet early on with consulting engineers:

- Determine types and number of filters to be tested.
- The number of test filters offered by vendors is limited and scheduling needs to be done well in advance of the project.
- Contracts will need to be negotiated with the vendors. Test filters are not free.

Have a goal of what information you want to get from the tests.

- Solids Removal.
- Ease of operation.
- Maintenance time, repair costs.
- Responsiveness of the vendors.



Pilot Test: Filter Site



Close to source of water to be treated.

Large enough to accommodate filters to be tested.

Pilot Test: Water Source



Process stream used for the pilot test should be the same as what will be used for the permanent installation.

Pilot Test: Power Supply



A power supply sufficient for all filters, pumps, and ancillary equipment will be needed.

Filter manufacturers will be able to supply data for their units.

Pilot Test: Daily Checks

FILTER #1: DAILY CHECK SHEET

Date: _____

Time: _____

Test Number _____

Op's Initials: _____

Local Panels		Turbidimeter				Particle Counter
Check for power and data displays	Clean lens	Clean lamp and glass under lamp	Drain and clean sample collection cell	If reading zero, check for burned out bulb.	Flush tubing as required	Clean strainers and tubing

Sample Collection					
TSS			Turbidity (Hand Meter)		
Influent Grab mg/l *	Influent Composite mg/l ¹	Effluent Grab mg/l	Effluent Composite mg/l ²	Effluent NTU	Secondary Effluent Channel NTU
N/A					

Data Readouts					
Influent Flow gpm	Headloss (Goal <2" change)	Pump Pressure (Goal 40 psi)	Air Pressure (Goal 5 psi)	Effluent NTU	Effluent Particle Size

Sample Flow Rates (Timed measurement with graduated cylinder)		Filter Flow
Effluent Turbidimeter (Goal 400-600ml/min)	Effluent Particle Size (Goal 100 ml/min)	(If filter is not up to setpoint, shut unit down and clean inlet strainer.)

Comments:

Determine Frequency

Be Consistent with checks, corrections, and adjustments.

Coordinate sampling with equipment checks.

Document findings.

Pilot Test: On Line Solids Meters

- **Turbidity Meters**
 - Require routine cleaning.
 - Flow rate adjustments need to be made based on vendor/consultant guidelines.

- **Particle Counters**
 - Problematic with frequent plugging.
 - Flow rates were recommended, but difficult to maintain.



Pilot Test: Sampling

Composite Samples

- Allow for 24 hour sampling.
- 15-30 minute intervals recommended.
- Lab results can be compared to electronic data.

▪ Grab Samples

- Taken at time of equipment check.
- Results can be compared to on-line meters at time of sample.
- Designate specific sample points.

- All Samples can be stored and tested later.





Pilot Test: Samples

- **Sample Containers**
 - One-liter bottles for grab samples.
 - Ten-liter bottles for composites.
 - Pre-labeled

- **Green Transportation for delivery to lab.**



Pilot Test: Lab Tests

- **Turbidity Meter**
 - Additional data to augment online meters.
 - Use for composite and grab samples.
 - Hint: Pour sample into vials and allow to reach room temperature before running samples. Cold sample will fog the glass.
- **Suspended Solids**
 - Standard test as used for plant effluent.
 - Volume for lab tests may need to be adjusted when doing PE or upset testing.



Pilot Test: Primary Effluent Testing

- **PE/Secondary Effluent**
 - PE diluted to ~50 mg/l to simulate high flow conditions.
 - Possible use of filters is to reduce effluent suspended solids to meet 85% removal and mass load requirements.
- **Dilution**
 - PE and SE mixed in injection chamber of off-line chlorine contact chamber.
 - 4" Chlorine line used to move PE from aeration basins to filters.
 - Suspended solids probe used to measure solids level and make dilution at the contact chamber.




Pilot Test: Plant Upset Testing

- **Mixed Liquor/Secondary Effluent**
 - ML diluted to ~25 mg/l to simulate upset of secondary treatment process.
 - Possible use of filters is to reduce effluent suspended solids during a plant upset to meet permit limits.
- **Dilution**
 - ML and SE mixed in injection chamber of off-line chlorine contact chamber.
 - 4" Chlorine line used to move ML from channel by secondary clarifiers to filters.
 - Suspended solids probe used to adjust flows to reach target.
 - Dilution not an exact science.



Pilot Test: Experience Gained

- **Plan Ahead**
 - Samplers or other equipment may have a long delivery time.
- **Know Your Limitations**
 - Staffing requirements may be greater than anticipated.
 - A student or intern to check the filters and/or run lab samples would be an option.
- **Separate filters from ancillary equipment**
 - Problems with online meters or other equipment may not be indicative of filter performance.





Pilot Study Results - Outline

- Objectives of pilot filter studies
- Pilot testing program and scope
- Pilot test program data / results
- Summary of performance results



Pilot Filter Testing Program Objectives

Principal objective:

- Evaluate performance of filters with specific consideration of the recycled criteria and NPDES requirements

Specific Objectives of the Pilot Testing Program:

- Determine/Confirm design criteria
- Evaluation of the filters' reliability, operational and maintenance requirements
- Determination of the backwash requirements



Pilot Filter Testing Program Scope

Testing of the following three filter technologies:

- **Granular – Continuous Backwash Up-flow (Blue Water Technologies)**
- **Compressible Medium Filter (Schreiber)**
- **Disk Filter (Aqua Aerobics Systems)**

at the following three filtration rates:

- **Average filtration rate**
- **Design filtration rate**
- **Peak design filtration rate**

for the following conditions:

- **Secondary effluent filtration without chemical addition**
- **Secondary effluent filtration with chemical addition**
- **Primary effluent filtration and upset simulation testing**



Pilot Test Program

Net testing : 20 weeks

- Total of 31 tests for each pilot filter system
- Each test is between 2 and 7 days
- 25 tests for secondary effluent filtration without chemical addition : about 14 weeks
- Two tests for chemical addition : approximately three weeks
- One test for simulation of upstream upsets: approximately one week
- Three tests for primary effluent filtration: Approximately 10 days

Pilot Filter Units

**Aqua Aerobic
Systems cloth disk
filter**

**Schreiber
compressible media
filter**

**Blue Water
Technologies granular
media filter**



Pilot Cloth Disk Filter



Pilot Upflow Continuous Backwash Granular Filter





Pilot Compressible Medium Filter



Pilot Filters – Design Criteria

	Filtration Surface Area, ft ²	Hydraulic Loading Rate, gpm/ft ²			Medium Properties				
		Average	Design	Increased Design	Medium Depth, inches	Effective Size	Porosity %	Compress ratio %	Media Type
Continuous Backwash Granular Filter	12	3.5	5	6-6.5	60	0.95 mm	40	N/A	Sand
Compressible Medium Filter	2.25	20	30	35-40	30	0.17 ^(a)	85	5-40	Synthetic
Cloth Disk Filter	12	3.25	6	7	0.2	10 μM		N/A	Pile Cloth



Evaluation of Filtration Technologies Performance Criteria

Turbidity / TSS removal

Headloss development

Backwash reject ratio

Chemical aid requirements


Particle size distribution modification

Turbidity and TSS Requirements/Objectives

	Parameter	Objective
Turbidity (NTU)	Daily Average	< 2
	Not to exceed more than 5% of the time	5
	Cannot exceed at all times	10
TSS (mg/l)	Monthly Average	< ~ 4 - 5
	Daily Maximum	< ~ 10 - 15


MWMC Compressible Medium Filter Turbidity Removal Performance

Influent and effluent turbidity values for CMF
between 07-14-2008 and 07-21-2008




Pilot Filter Testing Program

Summary of Average Effluent Turbidity Results



Pilot Filter Testing Program


Summary of Average Effluent Turbidity Results



Pilot Filter Testing Program - Summary of Average Influent and Effluent Turbidity Results

Average Influent and Effluent Turbidity Values (no chemical)

Influent
 Cloth Disk Filter
 Granular Filter
 Compressible Medium Filter





Summary of Turbidity Results Secondary Effluent Filtration without Chemical addition

Class A recycled water turbidity requirements are expected to be achieved with all three filtration technologies tested for average secondary effluent turbidities up to approximately 5 NTU without chemical addition


The turbidity removal performance of the three filters was observed to be similar. Average turbidity removal efficiency was approximately 50 to 55 percent for all three filters

Average observed effluent turbidity values were less than 1.8 to 2.0 NTU for all three filtration technologies for the majority of the tests




Pilot Filter Testing Program

Average TSS (composite samples) Results for Individual Test



Pilot Filter Testing Program

Overall Average TSS (composite samples) Results





Summary of TSS Results

Secondary Effluent Filtration without Chemical addition

Future discharge TSS concentration requirements are expected to be achieved with all three filtration technologies for secondary effluent TSS values up to approximately 25 mg/L without chemical addition.


The average effluent TSS was less than 5 mg/L for all three filters for the majority of the tests during normal plant operating conditions.

The TSS removal performance of the three filters was observed to be similar. The removal performance of CDF appears to be approximately 15-20 percent higher compared to CMF and GCBF.

Without chemical addition, average TSS removal efficiency was between 60 and 70 percent.

Summary of Backwash Water Ratio Results

Average Backwash Water Ratio for Secondary Effluent Filtration Tests without Chemical Addition



For 10 mgd average plant flow:

% 2 Backwash Reject Ratio means 0.2 MGD returned to headworks : average plant flow increases to 10.2 mgd

% 15 Backwash Reject Ratio means 1.5 MGD returned to headworks : average plant flow increases to 11.5 mgd



Summary of Backwash Results Secondary Effluent Filtration without Chemical addition

Backwash water ratio was observed to be between 1 percent and 5 percent for CMF and CDF for most tests. Average BWR was around 3 – 4 percent.


Backwash water ratio for GCBF was observed to be significantly higher compared to CMF and CDF. Average BWR was approximately 25 percent.

For actual installation with similar loading conditions, backwash water ratio is expected to be between 1 percent and 2 percent for CMF and CDF.

For actual installation with similar loading conditions, backwash water ratio is expected to be between 10 percent and 15 percent for GCBF.

MWMC Cloth Disk Filter Headloss Development


Headloss development for Cloth Disk Filter
07-10-2008 (filtration rate 3.2 gpm/ft² - 6.0 gpm/ft²)



MWMC Compressible Medium Filter Headloss Development

Headloss development versus time for CMF between
09-08-2008 and 09-15-2008

— headloss, ft






Summary of Headloss Results Secondary Effluent Filtration without Chemical addition

Headloss development (through the medium) varies significantly between the three filtration technologies:

- **CDF: Headloss development ranged between 0.4 feet and 0.9 feet with an average value of approximately 0.7 feet.**
- **CMF: Headloss development ranged between 0.6 feet and 4.2 feet with an average value of approximately 1.6 feet.**
- **GCBF: Headloss development ranged between 1.2 feet and 4.3 feet with an average value of approximately 2.3 feet.**

Secondary Effluent Filtration with Chemical Addition Cloth Disk Filter


Influent and effluent turbidity values for CDF with chemical addition
9-22-2008





Chemical addition tests

Cloth Disk Filter - Impacts on headloss development



Metropolitan Wastewater Management Commission



partners in wastewater management

Kennedy/Jenks Consultants
Engineers & Scientists



Summary of Chemical Addition Results

Turbidity removal efficiency increased to 70-75 percent with chemical addition for all three filters.

TSS removal efficiency increased to 80-85 percent with chemical addition for all three filters.

With chemical addition, compliance with Class A recycled water requirements is expected for secondary effluent turbidity values up to approximately 8 NTU.

With chemical addition, compliance with effluent TSS concentration requirements of 10 mg/L is expected for secondary effluent TSS values up to approximately 40 mg/L.



Summary of Chemical Addition Results

Filtration removal efficiency increases with successful chemical addition, but it was observed to decline typically after 1 to 3 hours of chemical addition.

Backwash Water Ratio increased significantly for CMF and CDF (e.g., 5 to 10 times) as a result of chemical addition.

Medium blinding was observed to be a typical operational problem with chemical addition.

Chemical addition should be exercised only to meet recycled water requirements when necessary for a short period (e.g., one hour) during one filtration cycle.




Evaluation of Filtration Performance Particle Size Distribution Modification

**Especially important to ensure required
disinfection efficiency**

**The removal of particles between ~ 5 and
15 to 20 micron in size is crucial to
increase disinfection efficiency**

Upflow Granular Continuous Backwash Filter Effect of Chemical Addition on Particle Size Distribution

Effluent particle size distribution versus time for CBGF (with chemical addition 50-10-20 ppm)





QUESTIONS & COMMENTS

Bill Bennett

bill.e.bennett@ci.eugene.or.us

(541) 682 - 8618

Onder Caliskaner

ondercaliskaner@kennedyjenks.com

(916) 858 - 2738


Metropolitan Wastewater Management Commission




partners in wastewater management

Kennedy/Jenks Consultants
Engineers & Scientists


Upset Simulation Turbidity Results for CDF



Upset Simulation Turbidity Results for CMF




Upset Simulation Turbidity Results for UGCBF



Primary Effluent Filtration TSS Results

Primary Effluent Filtration
Influent and Effluent TSS Values





Summary of Results

Primary Effluent Filtration Tests

For primary effluent filtration, the filters' removal performances were comparable.

TSS removal efficiencies were observed to range between 40 percent and 75 percent for the three filtration technologies. The removal performance of CMF appears to be approximately 10 percent higher compared to CDF and GCBF.

For primary effluent filtration, the BWR ratios were observed to be between 15 and 20 percent for CDF and CMF. The BWR ratio was approximately 25 percent for GCBF.